



NOTES CONCERNING FIRE HYDRANTS:

1. DRAINAGE BED SHALL CONSIST OF CRUSHED STONE OR COARSE GRAVEL WITH COARSE SAND; MIN. VOL. 7 CU. FT. DRAIN BED SHALL EXTEND A MIN. 6" ABOVE DRAIN OUTLET.
- *2. IF DISTANCE IS GREATER THAN 17" BETWEEN FIRE HYDRANT AND VALVE, USE 6" PVC NIPPLE WITH M.J. RETAINER GLANDS AND CONCRETE BLOCK THE FIRE HYDRANT
3. FIRE HYDRANTS TO BE BLOCKED AGAINST FIRM SOIL AS SHOWN.
4. ALL HYDRANTS SHALL BE INSTALLED PLUMB.
5. LARGE NOZZLE FACES ROAD, UNLESS OTHERWISE NOTED. ROTATE BARREL AS REQUIRED.
6. HYDRANT SHOULD NOT BE SET CLOSER THAN 4' TO OBSTRUCTIONS THAT ARE IN LINE WITH NOZZLE.
7. ANCHOR TEE, VALVE, ANCHOR COUPLING & F.H. CONSTITUTE FIRE HYDRANT ASSEMBLY
8. FIRE HYDRANT ASSEMBLY TO BE ANCHORED TO THE MAIN



PREPARED BY: THE CITY OF SULPHUR SPRINGS ENGINEERING DEPARTMENT

CITY OF SULPHUR SPRINGS
DEVELOPMENT MANAGEMENT MANUAL
DETAIL DRAWINGS

FIRE HYDRANT ASSEMBLY
DETAIL

SCALE: NTS
DATE: 11.20.2013
DR. BY:
CK. BY:

DRAWING NUMBER

FIG.-1.02