



**NOTES:**

1. VALVE TO BE AMERICAN FLOW CONTROL (OR APPROVED EQUAL).
2. JOINT TYPE TO BE MEGALUG RESTRAINTS (OR APPROVED EQUAL).
3. VALVE AND JOINT ASSEMBLIES SHALL BE WRAPPED IN POLYETHYLENE ACCORDING TO AWWA C105.
4. ALL BURIED VALVES SHALL BE PROVIDED W/EXTENSION STEM OPERATOR W/ 2" SQ. AWWA NUT IF VALVE OPERATING NUT IS 5' BELOW SURFACE. NUT IS TO INDICATE DIRECTION OF ROTATION TO OPEN VALVE.
3. CLEAN VALVE BOX OF ALL DEBRIS AND SOIL.

TYPICAL VALVE, VALVE BOX AND  
EXTENSION INSTALLATION DETAIL  
NOT TO SCALE



PREPARED BY: THE CITY OF SULPHUR SPRINGS ENGINEERING DEPARTMENT

CITY OF SULPHUR SPRINGS  
DEVELOPMENT MANAGEMENT MANUAL  
DETAIL DRAWINGS

GATE VALVE INSTALLATION  
DETAIL

SCALE: NTS  
DATE: 4.09.2015  
DR. BY:  
CK. BY:

DRAWING NUMBER

**FIG.-1.04**